

# UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
 Myrtle Creek, Oregon 97457  
 (541) 863-5201 Fax: (541) 863-6199  
 E-mail: Lab@URCmail.net  
 Internet: http://ChemLab.cc  
 ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 6101335

Camas Valley School  
 P O Box 57  
 Camas Valley, OR 97416

Project: Lead & Copper  
 Project #: Lead and Copper 2016  
 Client Contact: Garrett Moniz  
 PWSID#: 4190541

Date Reported: 10/25/16  
 Date Received: 10/13/16 12:45  
 Sampled By:

### Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
6101335-01	Sample Location: Science Rm Sink 1									
Lead		1030	0.008	mg/L	0.002	0.02	10/13/16 11:16	10/14/16	DJP	
Copper			0.106	mg/L	0.010	1.3	10/13/16 11:16	10/14/16	DJP	
6101335-02	Sample Location: Science Rm Sink 2									
Lead		1030	0.014	mg/L	0.002	0.02	10/13/16 11:16	10/14/16	DJP	
Copper			0.294	mg/L	0.010	1.3	10/13/16 11:16	10/14/16	DJP	
6101335-03	Sample Location: Science Rm Sink 3									
Lead		1030	<b>0.022</b>	mg/L	0.002	0.02	10/13/16 11:17	10/18/16	DJP	CON-1
Copper			0.230	mg/L	0.010	1.3	10/13/16 11:17	10/18/16	DJP	
6101335-04	Sample Location: Science Rm Sink 4									
Lead		1030	0.006	mg/L	0.002	0.02	10/13/16 11:17	10/14/16	DJP	
Copper			0.105	mg/L	0.010	1.3	10/13/16 11:17	10/14/16	DJP	
6101335-05	Sample Location: Science Rm Sink 5									
Lead		1030	0.008	mg/L	0.002	0.02	10/13/16 11:18	10/14/16	DJP	
Copper			0.115	mg/L	0.010	1.3	10/13/16 11:18	10/14/16	DJP	
6101335-06	Sample Location: Science Rm Sink 6									
Lead		1030	<b>0.043</b>	mg/L	0.002	0.02	10/13/16 11:18	10/18/16	DJP	CON-1
Copper			0.268	mg/L	0.010	1.3	10/13/16 11:18	10/18/16	DJP	
6101335-07	Sample Location: Science Rm Sink 7									
Lead		1030	<b>0.027</b>	mg/L	0.002	0.02	10/13/16 11:19	10/18/16	DJP	CON-1
Copper			0.317	mg/L	0.010	1.3	10/13/16 11:19	10/18/16	DJP	
6101335-08	Sample Location: Science Rm Sink 8									
Lead		1030	0.017	mg/L	0.002	0.02	10/13/16 11:19	10/14/16	DJP	
Copper			0.238	mg/L	0.010	1.3	10/13/16 11:19	10/14/16	DJP	
6101335-09	Sample Location: Science Back Rm Sink									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



# UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
 Myrtle Creek, Oregon 97457  
 (541) 863-5201 Fax: (541) 863-6199  
 E-mail: Lab@URCmail.net  
 Internet: http://ChemLab.cc  
 ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 6101335

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
		1030	0.003	mg/L	0.002	0.02	10/13/16 11:20	10/14/16	DJP	
			0.105	mg/L	0.010	1.3	10/13/16 11:20	10/14/16	DJP	
6101335-10	Sample Location: North Annex Lobby Drinking Fountain									
		1030	0.005	mg/L	0.002	0.02	10/13/16 11:27	10/14/16	DJP	
			0.275	mg/L	0.010	1.3	10/13/16 11:27	10/14/16	DJP	
6101335-11	Sample Location: North Annex Girls Restroom Basin									
		1030	0.004	mg/L	0.002	0.02	10/13/16 11:28	10/14/16	DJP	
			1.338	mg/L	0.010	1.3	10/13/16 11:28	10/18/16	DJP	CON-1
6101335-12	Sample Location: North Annex Boys Restroom Basin									
		1030	0.004	mg/L	0.002	0.02	10/13/16 11:29	10/14/16	DJP	
			1.214	mg/L	0.010	1.3	10/13/16 11:29	10/18/16	DJP	
6101335-13	Sample Location: Water House Outside Faucet									
		1030	0.006	mg/L	0.002	0.02	10/13/16 11:32	10/14/16	DJP	
			0.089	mg/L	0.010	1.3	10/13/16 11:32	10/14/16	DJP	
6101335-14	Sample Location: Football Field									
		1030	0.002	mg/L	0.002	0.02	10/13/16 12:10	10/14/16	DJP	
			0.015	mg/L	0.010	1.3	10/13/16 12:10	10/14/16	DJP	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



## UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
Myrtle Creek, Oregon 97457  
(541) 863-5201 Fax: (541) 863-6199  
E-mail: Lab@URCmail.net  
Internet: <http://ChemLab.cc>  
ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 6101335

### Qualifiers and Definitions

CON-1	Results confirmed by duplicate analysis.
DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

---

Tom Williams, Laboratory Manager