

UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6101310

Camas Valley School	Project: Lead & Copper	Date Reported: 10/25/16
P O Box 57	Project #: Lead/Copper 2016	Date Received: 10/13/16 10:00
Camas Valley, OR 97416	Client Contact: Garrett Moniz	Sampled By: Garrett Moniz
	PWSID#: 4190541	

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
6101310-01	Sample Location: Boys Restroom Basin/Main Building Upstairs									
Lead		1030	ND	mg/L	0.002	0.02	10/13/16 07:12	10/14/16	DJP	
Copper			0.042	mg/L	0.010	1.3	10/13/16 07:12	10/14/16	DJP	
6101310-02	Sample Location: Sink Staff Lounge									
Lead		1030	0.004	mg/L	0.002	0.02	10/13/16 07:14	10/14/16	DJP	
Copper			0.837	mg/L	0.010	1.3	10/13/16 07:14	10/14/16	DJP	
6101310-03	Sample Location: Main Building/Rm 4 Sink									
Lead		1030	0.036	mg/L	0.002	0.02	10/13/16 07:16	10/18/16	DJP	CON-1
Copper			1.855	mg/L	0.010	1.3	10/13/16 07:16	10/18/16	DJP	CON-1
6101310-04	Sample Location: Main Building/Rm 4 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/13/16 07:17	10/14/16	DJP	
Copper			ND	mg/L	0.010	1.3	10/13/16 07:17	10/14/16	DJP	
6101310-05	Sample Location: Girls Restroom Basin/Main Building Upstairs Right									
Lead		1030	0.005	mg/L	0.002	0.02	10/13/16 07:20	10/14/16	DJP	
Copper			0.193	mg/L	0.010	1.3	10/13/16 07:20	10/14/16	DJP	
6101310-06	Sample Location: Girls Restroom Basin/Main Building Upstairs Left									
Lead		1030	0.002	mg/L	0.002	0.02	10/13/16 07:21	10/14/16	DJP	
Copper			0.396	mg/L	0.010	1.3	10/13/16 07:21	10/14/16	DJP	
6101310-07	Sample Location: Rm. 7/Main Building Sink									
Lead		1030	0.014	mg/L	0.002	0.02	10/13/16 07:23	10/14/16	DJP	
Copper			0.219	mg/L	0.010	1.3	10/13/16 07:23	10/14/16	DJP	
6101310-08	Sample Location: Rm. 8/Main Building Right Sink									
Lead		1030	0.002	mg/L	0.002	0.02	10/13/16 07:26	10/14/16	DJP	
Copper			0.134	mg/L	0.010	1.3	10/13/16 07:26	10/14/16	DJP	
6101310-09	Sample Location: Girls Restroom/Main Building Downstairs Right Basin									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6101310

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	0.007	mg/L	0.002	0.02	10/13/16 07:45	10/18/16	DJP	
Copper			2.704	mg/L	0.010	1.3	10/13/16 07:45	10/18/16	DJP	CON-1
6101310-10	Sample Location: Girls Restroom/Main Building Downstairs Left									
Lead		1030	ND	mg/L	0.002	0.02	10/13/16 07:46	10/14/16	DJP	
Copper			1.327	mg/L	0.010	1.3	10/13/16 07:46	10/18/16	DJP	CON-1
6101310-11	Sample Location: Boys Restroom/Main Building Downstairs Basin Right									
Lead		1030	0.006	mg/L	0.002	0.02	10/13/16 07:48	10/14/16	DJP	
Copper			0.189	mg/L	0.010	1.3	10/13/16 07:48	10/14/16	DJP	
6101310-12	Sample Location: Boys Restroom/Main Building Downstairs Basin Left									
Lead		1030	0.006	mg/L	0.002	0.02	10/13/16 07:49	10/14/16	DJP	
Copper			0.124	mg/L	0.010	1.3	10/13/16 07:49	10/14/16	DJP	
6101310-13	Sample Location: Main Building/Upstairs Hall Drinking Fountain									
Lead		1030	0.007	mg/L	0.002	0.02	10/13/16 07:52	10/14/16	DJP	
Copper			0.071	mg/L	0.010	1.3	10/13/16 07:52	10/14/16	DJP	
6101310-14	Sample Location: Main Building/Downstairs Hall Drinking Fountain									
Lead		1030	0.005	mg/L	0.002	0.02	10/13/16 07:56	10/14/16	DJP	
Copper			0.028	mg/L	0.010	1.3	10/13/16 07:56	10/14/16	DJP	
6101310-15	Sample Location: Main Building/Downstairs Rm. 15 Sink									
Lead		1030	0.008	mg/L	0.002	0.02	10/13/16 08:00	10/14/16	DJP	
Copper			0.252	mg/L	0.010	1.3	10/13/16 08:00	10/14/16	DJP	
6101310-16	Sample Location: Main Building/Cafeteria Sink									
Lead		1030	0.004	mg/L	0.002	0.02	10/13/16 08:05	10/14/16	DJP	
Copper			0.198	mg/L	0.010	1.3	10/13/16 08:05	10/14/16	DJP	
6101310-17	Sample Location: West Annex/Rm 21 Sink									
Lead		1030	0.015	mg/L	0.002	0.02	10/13/16 08:15	10/14/16	DJP	
Copper			0.516	mg/L	0.010	1.3	10/13/16 08:15	10/14/16	DJP	
6101310-18	Sample Location: West Annex/Rm 21 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/13/16 08:16	10/14/16	DJP	
Copper			0.598	mg/L	0.010	1.3	10/13/16 08:16	10/14/16	DJP	
6101310-19	Sample Location: West Annex/Boys Restroom Basin									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6101310

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	ND	mg/L	0.002	0.02	10/13/16 08:25	10/14/16	DJP	
Copper			0.751	mg/L	0.010	1.3	10/13/16 08:25	10/14/16	DJP	
6101310-20	Sample Location: West Annex/Girls Restroom Basin									
Lead		1030	0.006	mg/L	0.002	0.02	10/13/16 08:25	10/14/16	DJP	
Copper			0.721	mg/L	0.010	1.3	10/13/16 08:25	10/14/16	DJP	
6101310-21	Sample Location: Gym Lobby/Girls Restroom Basin									
Lead		1030	ND	mg/L	0.002	0.02	10/13/16 08:27	10/14/16	DJP	
Copper			0.769	mg/L	0.010	1.3	10/13/16 08:27	10/14/16	DJP	
6101310-22	Sample Location: Gym Lobby/Boys Restroom Basin									
Lead		1030	0.002	mg/L	0.002	0.02	10/13/16 08:29	10/14/16	DJP	
Copper			0.617	mg/L	0.010	1.3	10/13/16 08:29	10/14/16	DJP	
6101310-23	Sample Location: Gym Lobby/Drinking Fountain									
Lead		1030	0.002	mg/L	0.002	0.02	10/13/16 08:33	10/14/16	DJP	
Copper			0.701	mg/L	0.010	1.3	10/13/16 08:33	10/14/16	DJP	
6101310-24	Sample Location: Gym Boys Locker Room/Sink									
Lead		1030	ND	mg/L	0.002	0.02	10/13/16 08:37	10/14/16	DJP	
Copper			ND	mg/L	0.010	1.3	10/13/16 08:37	10/14/16	DJP	
6101310-25	Sample Location: Gym Girls Locker Room/Basin									
Lead		1030	0.003	mg/L	0.002	0.02	10/13/16 08:40	10/14/16	DJP	
Copper			0.047	mg/L	0.010	1.3	10/13/16 08:40	10/14/16	DJP	
6101310-26	Sample Location: Gym Girls Locker Room/Drinking Fountain									
Lead		1030	0.005	mg/L	0.002	0.02	10/13/16 08:43	10/14/16	DJP	
Copper			0.084	mg/L	0.010	1.3	10/13/16 08:43	10/14/16	DJP	
6101310-27	Sample Location: Gym Boys Locker Room/Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/13/16 08:45	10/14/16	DJP	
Copper			ND	mg/L	0.010	1.3	10/13/16 08:45	10/14/16	DJP	
6101310-28	Sample Location: Water House/Sink									
Lead		1030	0.006	mg/L	0.002	0.02	10/13/16 08:55	10/14/16	DJP	
Copper			0.018	mg/L	0.010	1.3	10/13/16 08:55	10/14/16	DJP	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6101310

Qualifiers and Definitions

QM-4X	The spike recovery was outside of QC acceptance limits for the MS and/or MSD due to analyte concentration at 4 times or greater the spike concentration. The QC batch was accepted based on LCS/SRM recovery within the acceptance limits.
CON-1	Results confirmed by duplicate analysis.
DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager